

## Viral Filtration Efficiency (VFE) Final Report

---

Test Article: mPactAirDL Type 9001 Test XSP2P  
Purchase Order: 021021  
Study Number: 1391951-S01  
Study Received Date: 23 Feb 2021  
Testing Facility: Nelson Laboratories, LLC  
6280 S. Redwood Rd.  
Salt Lake City, UT 84123 U.S.A.  
Test Procedure(s): Standard Test Protocol (STP) Number: STP0007 Rev 16  
Deviation(s): None

**Summary:** The VFE test is performed to determine the filtration efficiency of test articles by comparing the viral control counts upstream of the test article to the counts downstream. A suspension of bacteriophage  $\Phi$ X174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at  $1.1 - 3.3 \times 10^3$  plaque forming units (PFU) with a mean particle size (MPS) of  $3.0 \mu\text{m} \pm 0.3 \mu\text{m}$ . The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Either  
Test Area:  $\sim 40 \text{ cm}^2$   
VFE Flow Rate: 28.3 Liters per minute (L/min)  
Conditioning Parameters:  $85 \pm 5\%$  relative humidity (RH) and  $21 \pm 5^\circ\text{C}$  for a minimum of 4 hours  
Positive Control Average:  $2.3 \times 10^3$  PFU  
Negative Monitor Count:  $< 1$  PFU  
MPS:  $2.9 \mu\text{m}$



Mikell Goldsberry electronically approved  
Study Director

Mikell Goldsberry

12 Mar 2021 06:23 (+00:00)  
Study Completion Date and Time

**Results:**

Test Article Number	Percent VFE (%)
1	99.7
2	99.8
3	99.7
4	>99.9 <sup>a</sup>
5	99.7

<sup>a</sup> There were no detected plaques on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

## Bacterial Filtration Efficiency (BFE) Final Report

---

Test Article: mPactAir DL Type 9001 Test XSP2P  
Purchase Order: 021021  
Study Number: 1391952-S01  
Study Received Date: 23 Feb 2021  
Testing Facility: Nelson Laboratories, LLC  
6280 S. Redwood Rd.  
Salt Lake City, UT 84123 U.S.A.  
Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18  
Deviation(s): None

**Summary:** The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at  $1.7 - 3.0 \times 10^3$  colony forming units (CFU) with a mean particle size (MPS) of  $3.0 \pm 0.3 \mu\text{m}$ . The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-19 and EN 14683:2019, Annex B.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Either  
BFE Test Area:  $\sim 40 \text{ cm}^2$   
BFE Flow Rate: 28.3 Liters per minute (L/min)  
Conditioning Parameters:  $85 \pm 5\%$  relative humidity (RH) and  $21 \pm 5^\circ\text{C}$  for a minimum of 4 hours  
Positive Control Average:  $1.9 \times 10^3$  CFU  
Negative Monitor Count:  $< 1$  CFU  
MPS:  $2.9 \mu\text{m}$



Mikell Goldsberry electronically approved  
Study Director

Mikell Goldsberry

11 Mar 2021 01:23 (+00:00)  
Study Completion Date and Time

**Results:**

Test Article Number	Percent BFE (%)
1	99.5
2	99.4
3	99.4
4	99.5
5	99.7

The filtration efficiency percentages were calculated using the following equation:

$$\% BFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

## Differential Pressure (Delta P) Final Report

Test Article: mPactAir DL Type 9001 Test XSP2P  
 Purchase Order: 021021  
 Study Number: 1391950-S01  
 Study Received Date: 23 Feb 2021  
 Testing Facility: Nelson Laboratories, LLC  
 6280 S. Redwood Rd.  
 Salt Lake City, UT 84123 U.S.A.  
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18  
 Deviation(s): None

**Summary:** The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test complies with EN 14683:2019, Annex C and ASTM F2100-19.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Either  
 Delta P Flow Rate: 8 Liters per minute (L/min)  
 Conditioning Parameters: 85 ± 5% relative humidity (RH) and 21 ± 5°C for a minimum of 4 hours

**Results:**

Test Article Number	Delta P (mm H <sub>2</sub> O/cm <sup>2</sup> )	Delta P (Pa/cm <sup>2</sup> )
1	5.6	54.7
2	6.6	64.3
3	6.1	59.4
4	5.8	56.6
5	5.8	56.8



Christopher Acker electronically approved  
 Study Director

Christopher Acker

04 Mar 2021 23:46 (+00:00)

Study Completion Date and Time